

Photometric Data



EL-DL2 - Corridor Luminaire

NON-MAINTAINED	2m wide corridor	
Mounting Height (m)	Spacing 1 Lux Axial to Wall	Spacing 1 Lux Axial Between
2.00	4.56	9.82
2.40	5.18	11.40
2.50	5.31	11.80
2.60	5.45	12.12
2.70	5.55	12.48
2.80	5.66	12.80
2.90	5.75	13.10
3.00	5.83	13.44
3.10	5.90	13.80
3.20	5.95	14.08
3.30	5.96	14.38
3.40	5.95	14.66
3.50	5.90	14.94

MAINTAINED	2m wide corridor	
Mounting Height (m)	Spacing 1 Lux Axial to Wall	Spacing 1 Lux Axial Between
2.00	4.56	9.70
2.40	5.02	11.20
2.50	5.15	11.56
2.60	5.24	11.84
2.70	5.32	12.18
2.80	5.40	12.50
2.90	5.48	12.80
3.00	5.50	13.12
3.10	5.50	13.40
3.20	5.46	13.70
3.30	5.31	13.98
3.40	3.32	14.20
3.50	2.75	14.44

EL-DL3 - Open Area Luminaire

NON-MAINTAINED	Open Area to 0.5 Lux	
Mounting Height (m)	Spacing to Wall	Spacing Between
2.00	2.85	6.19
2.40	3.19	7.14
2.50	3.25	7.37
2.60	3.30	7.57
2.70	3.32	7.78
2.80	3.31	7.99
2.90	3.31	8.20
3.00	3.04	8.37
3.10	2.79	8.56
3.20	2.55	8.73

MAINTAINED	Open Area to 0.5 Lux	
Mounting Height (m)	Spacing to Wall	Spacing Between
2.00	2.76	6.08
2.40	3.04	6.96
2.50	3.08	7.20
2.60	3.04	7.41
2.70	2.93	7.61
2.80	2.70	7.78
2.90	2.47	7.95
3.00	2.19	8.15

NFW89/C - Corridor Luminaire

NON-MAINTAINED	2m wide corridor	
Mounting Height (m)	Spacing 1 Lux Axial to Wall	Spacing 1 Lux Axial Between
2.00	4.60	9.00
2.20	5.00	9.60
2.50	5.50	10.60
2.70	5.90	11.60
3.00	6.60	12.60
3.50	7.20	14.20
4.00	8.00	15.60
4.50	8.90	17.00
5.00	9.60	19.00
6.00	10.50	20.00
7.00	12.00	22.00

NFW89/O - Open Area Luminaire

NON-MAINTAINED	Open Area to 0.5 Lux	
Mounting Height (m)	Spacing to Wall	Spacing Between
2.00	3.32	6.79
2.20	3.61	7.50
2.50	4.03	8.49
2.70	4.31	9.05
3.00	4.67	9.90
3.50	5.37	11.31
4.00	6.01	12.59
4.50	6.51	13.86
5.00	7.00	15.13
6.00	7.64	17.39
7.00	7.14	19.23
8.00	5.44	20.51